

**CHECK KIST FOR SELE-APPRAISAL OF FIRE SAFETY IN  
SAW MILLS/TIMBER DEPOT**

Name and Address of the Saw Mill/Timber Depot :

NO. of Electrical Machines available in the premises :

*1.	Whether the place of Timber Depot/Saw Mill as easily approachable to Fire appliances?	Yes	No	---
*2.	Whether the width of main gate is minimum 4.5 meter?	Yes	No	---
*3.	Whether no overhead Electric bare wire is allowed in the compound or pass through the compound.	Yes	No	---
*4.	Whether the Timber Storage, working or process building are preferably of single storied structure? The ceiling height shall not exceed 8.0 meter.	Yes	No	N.A.
*5.	Whether the compartmentation is provided in between Boiler House/Furnace Room, Varnishing and Spray Painting sections and neighboring Timber. Depot/Saw Mill?	Yes	No	N.A.
*6.	Whether Boilers, either in the open or in a building shall be within 30.0 meters of a timber yard not within 15.0 meters or a building used for storage or processing of timber?	Yes	No	N.A.
*7.	Whether no building or open storage is within 4.5 meters of the compound wall?	Yes	No	---
*8.	Whether each working room has been provided with adequate number of exits not less than two in any case?	Yes	No	---
*9.	Whether no tack of timber has been exceeding 6.0 meters in height?	Yes	No	---
*10.	Whether all motors in wood working areas have been totally enclosed or pipes ventilated type (Clause 13.2)	Yes	No	---
*11.	Whether Electrical wiring for lighting in wood storage and process department have been enclosed in screwed steel conduits and those for power wring have been enclosed either in screwed screwed steel conduits or of a mineral insulated copper sheathed type (Clause 13.4)	Yes	No	---
*12.	Whether the fire Fighting Installations as per the enclosed Table-2 under Clause 14.2 of India Standard 6329:2000 are provided?	Yes	No	---
*13.	Whether a watchman, who will go round the property at 2 hourly intervals during non-working hours, has been provided?	Yes	No	---
*14.	Whether No Smoking or Cooking has been carried out in the premises as required (Clause 15.1)?	Yes	No	---
*15.	Whether "NO SMOKING" signs has been prominently exhibited as required (Clause 15.1)?	Yes	No	---
*16.	Whether the Timber Yards have been kept free of grass weeds and undergrowth as required (Clause 15.4)	Yes	No	---
*17.	Whether Good House Keeping is observed?	Yes	No	---

Place :

Signature of the Owner/Occupier  
of Saw Mill, Timber Depot with  
Designation and Office Seal.

Date :

Standard referred : Indian Standard 6329:2000" Code of Practice for Fire Safety of Industrial Building ,Saw Mills. Timber Depots and Wood Works"

Note: The Fire Safety Measures indicated with (\*marks) are mandatory.

